


Ø16±1,0

5Min

ANSI 52-1 Type Standard Applied ANSI C29.2 Main Dimensions D: 152 Н: 140 Creepage Distance 178 Rated M&E Failing Load 44kN Power frequency dry flashover voltage 60kV Power frequency wet flashover voltage 30kV Critical impulse flashover voltage (Positive) 100kV (Negative) 100kV Power frequency puncture voltage 80kV 5. ON. m Impact strength Radio-Influence Voltage Test Voltage to Ground 7.5kV Maximum RIV, at 1000kHz 50 μ V



Ø152 Max

## Design Standard Marker Num Sigh Audit Date Weight



Suspension Type Porcelain Insulator

JIANGXI QOCI ELECTRIC CO.,LTD

**ANSI 52-1** 

JIANGXI QOCI ELECTRIC CO.,LTD.

JIANGXI QOCI ELECTRIC CO.,LTD

JIANGXI QOCI ELECTRIC CO.,LTD.

 $17.5\pm0.8$