



Ref. Certif. No.

HU-005103

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCB

Name and address of the applicant

GACIA ELECTRICAL APPLIANCE CO., LTD
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang
Town, Yueqing 325603 Zhejiang
P.R. China

Name and address of the manufacturer

GACIA ELECTRICAL APPLIANCE CO., LTD
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang
Town, Yueqing 325603 Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

GACIA ELECTRICAL APPLIANCE CO., LTD
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang
Town, Yueqing 325603 Zhejiang
P.R. China

Ratings and principal characteristics

Ue=230/400VAC (1P); 400VAC (2P, 3P);
In=6/10/16/20/25/32/40/50/63A;
B/C-type; Icn=Ics=3,0kA;
Icn1=Icn; Uimp=4,0kV

Trademark / Brand (if any)

Gacia

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATB5

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24YXXN 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2024-09-23

Signature:

Wencai Zhang