



BV LCIE
CHINA
Number

N° 2366AS05CIFP49733

ATTESTATION of conformity with European Directives

Product: MCB
Reference ATB5/ATB6-HZ for Icn=4500A
ATB6-LZ/ATB6-Z/ATB6-L for Icn=6000A
Issued to GACIA ELECTRICAL APPLIANCE CO.,LTD.
Address No.1 Nanxijiang Road,Daqiao Industrial Zone,Beibaixiang Town,325603
Yueqing,Zhejiang,China
Manufacturer GACIA ELECTRICAL APPLIANCE CO.,LTD.
Type D; C and B
Ue=230/400V~(1P);230V~(1P+N);400V~(2P;3P;3P+N;4P)
In=6;10;16;20;25;32;40;50;63A
Icn=4500A and 6000A
Technical characteristics Ics=4500A and 6000A
Energy limit class: 3 (according to EN 60898-1)
Grid distance: 45mm
Ui=415V
Uimp=4kV
Screw diameter of load terminal =4,8mm

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60898-1:2019	B230011	24/04/2023

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), May 11st, 2023.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com