

ATTESTATION OF CONFORMITY

Issued to: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China

For the product: Circuit breakers for overcurrent protection

Trade name: GACIA

Type/Model: PB8H, PB8HN, PB8HQ, PB8H2, PB8N, PB8NN, PB8NQ, PB8N2, PB8LN, M80H,
M100, M80, N8BH, VB8H, DB10H

Ratings: 1P, 2P, 3P, 4P
Ue: 230 / 400 Vac for 1P, 400 Vac for 2P, 3P and 4P
In: 1, 2, 3, 4, 5, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63 A, B, C and D type
50 / 60 Hz, All poles are protected, Ics = 7,5 kA, Icn = Icn1 = 10 kA
The grid distance "a": 45 mm, Energy limiting class 3 for B and C type

Manufactured by: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China

Subject: Type Test

Requirements: EN 60898-1:2019, IEC 60898-1:2015, IEC 60898-1:2015/A1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports no 3317040.50 issued on 2020-10-29, 3307943.50 issued on 2015-11-19, 3305490.50 issued on 2013-11-15, 3303230.50 issued on 2012-05-02, 3302398.50 issued on 2011-06-27 and W0807018.50 issued on 2008-09-08.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 10 November 2020 Number: 3317040.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

